

Preliminary Report of Accident



1. Accident Type: Fatal Injury	2. Accident Classification Electrical	3. Date/Time of Accident 10/10/2010 12:57 PM	4. Date/Time of Death 10/12/2010 06:45 PM	5. Fatal Case No 16
6. Mine Information :				
a) Mining Company Name Martin Marietta Materials, Inc.		b) Mine Name SNYDER		c) Parent of Mining Company Martin Marietta Materials Inc
7. Mine Location : a) City Snyder		b) County Kiowa	c) State OK	8. Mine ID Number: 34-01651
9. Union: NO				
10. Primary Mineral Mined: CRUSHED & BROKEN GRANITE MINI	11. Number of Mine Employees: a) Total 24	b) Underground 21	c) Open Pit/Quarry 21	d) Mill/Prep Plant 3
12. Contractor Name: Hertzler Electrical Services		13. Union NO	14. Contractor ID Number: R495	
15. Contractor Address: a) City Marlow		b) County Stephans	c) State OK	d) Zip Code 73055
16. Number of Contractor Employees: a) Total 4		b) Underground 4	c) Open Pit/Quarry 4	d) Mill/Prep Plant 4
17. Number of Persons in Mine at Time of Accident: a) Mine Employees: 2 b) Contractor Employees: 4		18. Number of Persons Unaccounted For: a) Mine Employees: 0 b) Contractor Employees: 0		
19) Location of Accident ☐ 01-Underground ☒ 03-Open Pit ☐ 07-Advance Mining ☐ 30-Mill/Prep Plant ☐ Other (specify) ☐ 02-Surface at Underground ☐ 06-Dredge Mining ☐ 08-Retreat Mining ☐ 99-Office Facility				20. Mining Height: Feet Inches
21. Nonfatal Injuries: 2		22. Fatal Injuries: 1		
23. Victim Information :				
a) Name [REDACTED]		b) Age [REDACTED]		
c) Regular Job Title: Electrician		d) Activity at Time of Accident: Install GF Indicator Lights ☒ Contractor Employee		
24. Experience :				
Years Weeks Days a) Total: [REDACTED]		Years Weeks Days b) at the mine: [REDACTED]		c) at activity (23d) [REDACTED]
Years Weeks Days d) with Contractor [REDACTED]				
25. Autopsy Performed: NO		26. Mine Telephone No.: (580) 569-2393		
27. Description of Accident (include equipment involved, the exact location in the mine, and status of rescue and recovery operations): Three persons were installing ground fault indicator lights on the main 800 amp breaker when an arc flash occurred, injuring them. They were transported to a hospital for treatment where the victim died on October 12, 2010.				
The information provided in this notice is based on preliminary data ONLY and does not represent final determinations regarding the nature of the incident or conclusions regarding the cause of the accident.				
28. Equipment Manufacturer: Westinghouse Electric Co.		29. Model:		
30. District: M5000 South Central		32. Field Office: Norman OK		33. Event Number: 6547807
34. Accident Investigator: Gary Cook		35. MSHA Person Notified: Mike Dunlap Date 10/10/2010 Time 01:44 P		
36. Type of Report: Initial		37. Name of Preparer and Date Prepared: Mike Hancher MH Date 10/13/2010		
38. Reason For Amendment:				